BellacideTM 355 Cooling Tower Microbicide

Phosphonium Chloride81741-28-8

Effective in the Removal of...

- Bacteria
- Algae
- Slime
- Fungi
- Bacterial fouling

DIRECTIONS: Initial Dose: When the system is noticeably fouled, add 26 to 77 fluid ounces of BELLACIDETM 355 per 1000 gallons of water contained in the system. Repeat until control is achieved.

Subsequent Dose: When microbial control is evident, add 13 to 38 fluid ounces of BELLACIDE[™] 355 per 1000 gallons of water contained in the system. Repeat as needed to maintain control. Heavily fouled systems must be cleaned before treatment is begun. See label for further applications (pulp, paper & paperboard mills, and enhanced oil recovery) dosage rates.

HMIS®				NFPA
	Severe	4	Extreme	
Health3	Serious	3	High	Health
Flammability0	Moderate	2	Moderate	Flammability0
Physical Hazard0	Slight	1	Slight	Reactivity0
Personal ProtectionD	Minimal	0	Insignificant	Special PrecautionsNone